

CNO:48:CFO/Kalaburagi/School-NOC/2023
TO,

Date: 18-07-2023

The President /Principal
LITTLE FLOWER
English medium school
(CBSE) Kallahalli road
HOSAPETE town Vijayanagar dist.

Sub:- Issue of advice on requirement of fire prevention fire fighting and
evacuation measures required at LITTLE FLOWER English medium school
(CBSE) Kallahalli road HOSAPETE town Vijayanagar dist. Reg

Ref:- 1) Application letter Dated 03-07-2023
2) C.No.150/RFO/BLR/2023, Date-31-01-2017

With reference to the cited above subject and your letter ref:1, LITTLE FLOWER
English medium school (CBSE) Kallahalli road HOSAPETE town Vijayanagar dist was
inspected by the Regional fire Officer Ballari on 10/07/2023 and submitted his report vide
ref.2. As per his report the requirement of fire prevention fire fighting and evacuation
measures required in the building details are as follows.

A. Details of the premises:-

- | | | |
|--|---|--|
| 1. Address of the premises | : | The Principal
LITTLE FLOWER English medium
School (CBSE) Kallahalli road
HOSAPETE town Vijayanagar dist. |
| 2. Name & Address of the
Building Owner | : | The President /Principal
LITTLE FLOWER English medium
School (CBSE) Kallahalli road
HOSAPETE town Vijayanagar dist. |
| 3. Number of Building | : | One Building |



4. Number of floors : Ground + 3rd floor
5. Floor wise details of occupancy
- | | | |
|--------------|---|--|
| Ground Floor | : | 05 class rooms, 01 office staff room,
01 head mistress room & office |
| First floor | : | office staff room, class room, -06 no's |
| Second floor | : | Class room 7no's |
| Third floor | : | Science lab 01, Computer lab 01,
Library 01, A V L Hall &
extra Curriculum activities 01 |
6. Height of the Building : 09.90 meter
7. Site area : 36435. sq feet
8. Built-up area
- | | | |
|-----------------------|---|-----------------|
| Ground floor | : | 511.09 Sq. mtrs |
| 1 st floor | : | 620.24 Sq. mtrs |
| 2 nd floor | : | 620.24 Sq. mtrs |
| 3 rd floor | : | 620.24 Sq. mtrs |
| Total built up area | : | 2371.57 Sq mtrs |
9. Type of Construction : R C C Building
10. Surroundings
- | | | |
|-------|---|-------------------------|
| East | : | Hosapete to Sandur road |
| West | : | Open space |
| North | : | Open space |
| South | : | Open space |
11. Entrance and exist gate width : 01 entrance each of 15.00 mtrs width
has been provided.



B. On inspection of the school premises, the following fire prevention, fire fighting and evacuation measures are recommended and they are considered absolutely essential.

Details (1)	Existing (2)	Recommendation (3)
1. Approach to the Premise	the premises is accessible from 10.00 mtrs Wide road located on the Eastern side.	The requirement is complied with
2. Open space around the Building	East : 52.4 meter West : 32.2 meter North : 15.0 meter South : 5.0 meter	To be maintained as per Zonal regulation
3. Parking area	school bus and car, parking Provided located on Northern side.	Adequate
4. Number of Staircase	02 staircase provided located on western side from ground Floor to the terrace of width 1.20 meter	The existing staircases width to be extended to 2.0 meters

C. the following fire prevention, fire fighting and evacuation measures are recommended and they are considered absolutely essential:-

Details (1)	Existing (2)	Recommendation (3)
02. Hose reel hose	Not indicated	Recommended to Provide 01 no's Of hose reel hose system near the Staircases connected to terrace tank of 10,000 liter capacity each



**Hose reel hose and the system
Must be connected to booster
Pump of capacity (450LPM)**

03. Water storage tank : Not provided

Recommended to Provide
Over head water tank of
For each floor hose reel
Hose system.

04. Portable Fire
Extinguishers:-

Provided

1) 12 nos ABC fire
extinguishers each of
05 Kgs capacity water Co2
extinguishers

06 fire buckets with fine stand.
02 Nos ABC fire extinguishers
in lab room to provide.

Recommended to provide
04 nos ABC fire
Extinguishers of each floor

**GENARETOR/ELECTRIC
POWER ROOM**
02 Nos DCP fire extinguishers,

05. Assembly area

Safe assemble area for the
students to assemble in
emergencies provided.



6. Fire prevention Measures.

Not indicated

1). Explosive and Inflammable materials should not be stored in the premises.

2) Accumulation of combustible waste in and around the premises should be avoided.

3) The class room and other door shall not be kept locked/latched during working hours and shall be free from obstructions.

C C camaras to be provided all around the school building at the strategic locations.

Public address system to be provided throughout the school building with its console at the lobby or with management.

6) The one side and off side Emergency plans prepared and annually twice the mock drill evacuation conducted.

7. Escape Route

Directions in which the Students have to move in the event of any emergency have been indicated in the corridor/ staircase, on each floor.
(EXIST SIGN BOARD)

8. First Aid Box

Each floor One First Aid Box Is provided.



09. Fire Order

NIL


Notice boards indicating with Details of action to be taken by the employees in case of an Emergency/fire has been displayed with telephone Number of Hospet Station i.e 08394-230555 Fire & 101 and of near by Ambulance Service.

10. Training to Employees.

Two employees undergone training
R.A.Mundkur Fire & Emergency Services
Academy, Bannerughatta Road, Bangalore.
from 5-9-2013 to 7-9-2013
Shree Gangadhara D.S
,, Shaantha kumari

Hence this NOC is issued to **LITTLE FLOWER English medium school(CBSE) Kallahalli road HOSPET town Ballari Dist** subject to strict adherence of the conditions or laid down in this NOC and to check up the portable fire extinguishers & the Hose reels and to conduct mock drills periodically And the management must not extend the height of the building beyond 15.0 meters .and this NOC is valid for a period of one year from the date of issue. **And is renewable.**

Your's faithfully


CHIEF FIRE OFFICER
KARNATAKA FIRE AND
EMERGENCY SERVICES
KALABURAGI ZONE
KALABURAGI-585103

Copy to: The Regional Fire Officer Bellary